

Installation Instructions

Descriptions

The luminaire contains a constant-current driver and LED light sources. It works under technical conditions as the product labels indicate.

Technical Parameter

		LED Flood Light						
Power	320W		400W		500W			
Input Voltage	<input type="checkbox"/> 100~240V	<input type="checkbox"/> 100~277V	<input type="checkbox"/> 220~240V	<input type="checkbox"/> 120~277V	<input type="checkbox"/> 277~480V	<input type="checkbox"/> Other_____	Frequency	50/60Hz
Power Factor	0.95							
Working Environment	-40°C~+45°C, 10%~90%RH							
Bolt Torque	29Nm							
Mounting Height	0~35m							
Dimensions	665x425x225mm							
Net Weight1	16.3kg		16.3kg		16.3kg			
Net Weight2	21.2kg		21.7kg		22.8kg			
Project Area	0.283m ²							
Degree of Protection	<input type="checkbox"/> IP54 <input type="checkbox"/> IP65 <input type="checkbox"/> IP66 <input type="checkbox"/> IP67 <input type="checkbox"/> Other_____							

Notes: The above net weight is typical value;

N.W. No.1 is weight of luminaire;


N.W. No.2 is weight of luminaire+driver box

Applications


Architectural exterior lighting for single building and historical complex; flood lighting on buildings; indoor area lighting; landscape lighting; billboard lighting; medical, cultural and other establishment lighting; bar, club and other atmosphere lighting; port, air port and other traffic and parking area lighting.

Installation and Maintenance


Installation



1. Mount the luminaire. Fixate the bracket with fastened screws.




2. Loosen the biggest screw in the middle on the sides of bracket. Adjust to a proper angle. Fasten the screws.




3. Connect the wires with power supply input correctly. Keep the connection junction waterproof. Installation finished.

Cable Connectors



1. Connect the male and female connectors by aligning the indicative arrow on them.



2. Hold the nut on one terminal still, meanwhile, rotating clockwise till the one on the other terminals is tightened up. Otherwise the waterproof performance might be affected.

Installation Instructions

Wiring

Power Supply End	Earth wire	Neutral wire	Live wire
Fixture End	Yellow-green lead	Blue lead	Brown lead
	Green lead	White lead	Black lead

Caution

- a** Disconnect or turn off power before installation, maintenance and wiring.
- b** Cable connection must be insulated and waterproof.
- c** For luminaires with glass cover: the cover is made of tempered glass which shatters into small pieces without sharp edges when it breaks. Application condition: -30°C~100°C; maximum temperature rise $\Delta t 60^{\circ}\text{C}$.
- d** The light source of this luminaire is not replaceable. When the light source's lifetime comes to an end, it is the whole luminaire that should be replaced.


Warning: Danger! Electric shock risk!

(via IEC 60417-6042 (2011-11))




For luminaires with glass cover: The broken cover should be replaced.


Rectangle



Round



Minimum distance from the light source to the illuminated object: 0.1m.



The luminaire shall be installed by a qualified electrician and wired in accordance with the latest IEE electrical regulations or the national requirements.



This marking indicates that this product should not be disposed with other household wastes throughout the EU. To prevent possible harm to the environment or human health from uncontrolled waste disposal, recycle it responsibly to promote the sustainable reuse of material resources. To return your used device, please use the return and collection systems or contact the retailer where the product was purchased. They can take this product for environmental safe recycling

Remarks

1. This luminaire uses permanent connection on power supply with flexible cable and wires (60245 IEC57). Sufficient length of cable is reserved for connection to AC power. Protection over the connection joint and elimination of tensile force there should be ensured.
2. This luminaire uses type Z attachment: the external flexible cable or cord of this luminaire cannot be replaced; if the cord is damaged, the luminaire shall be destroyed.
3. Wiring: the connection to AC power should be operated on terminal blocks in a wiring box with a degree of protection at least equivalent to the luminaire, and there should be devices to fixate wires.
4. The luminaire can be mounted onto ordinary combustible surfaces.
5. The type of insulation between LV power supply and conductor control are listed as follows. The insulation maintenance can also rely on other external components (product) that connected to the same control bus. It is the responsibility of the control system designer, but not the luminaire manufacturer.
 - FELV control signal and LV power supply: basic insulation.
 - SELV control signal and LV power supply: reinforced insulation or double insulation.