Installation Instructions

Descriptions

The luminarie contains a constant-current driver and LED light sources. It works under technical conditions as the product labels indicate.

Technical Parameter


	LED Street Light				
Power	40W				
Input Voltage	□ 100~240V □ 100~277V □ 220~240V □ 120~277V □ 277~480V □Other Frequencey 50/60Hz				
Power Factor	0.95				
Working Environment	-40℃~+50℃, 10%~90%RH				
Bolt Torque	17Nm				
Mounting Height	3~6m				
Mounting Spacing	10~21m				
Dimensions	345x140x165mm				
Net Weight	2.6kg				
Project Area	0.049m ²				
Degree of Protection	□ IP54 □ IP65 □ IP66 □ IP67 □ Other				

Notes: The above net weight is typical value. The power above are maximum rated power of the model subject to tolerance of 10%.


Applications

Sub-trunk roads, paths, schools, residential areas, courtyards, etc.


Installation



1. Connect the wires to AC power input.




2. Loosen the two M10 hex socket head cap screws on the mounting sleeve.



3. Mount the light to the pole arm, and fasten the M10 screws. Installation finished.

Installation of NEMA Receptacle and Photocell




- Undo the two screws to remove the round cover and its white sealing washer.
 Thread the wires of the receptacle through the black sealing washer into the electrical compartment of luminaire. Keep the screw holes in alignment among the receptacle, sealing ring and luminaire, and fixate the receptacle with two M4x25 cross recessed countersunk head screws.
- 3.Plug in and fasten the photocell. Connect the wires in the electrical compartment.

Installation Instructions

Wiring

Power Supply End	Earth wire	Neutral wire	Live wire		
	Yellow-green lead	Blue lead	Brown lead		
Fixture End	Green lead	White lead	Black lead		
Caution					
a Disconnect or tur	Disconnect or turn off power before installation, maintenance and wiring.				
b Cable connection	Cable connection must be insulated and waterproof.				
pieces without sh	For luminaires with glass cover: the cover is made of tempered glass which shatters into small pieces without sharp edges when it breaks. Application condition: $-30^{\circ}C$ ~100°C; maximum temperature rise $\Delta t60^{\circ}C$.				
	The light source of this luminaire is not replaceable. When the light source's lifetime comes to an e it is the whole luminaire that should be replaced.				
/arning: Danger! Ele	ectric shock risk!				
(via IEC 604	417-6042(2011-11))	4			
or luminaires with g	ass cover: The broken	cover should be replace	ced.		
lectangle	$\sqrt{\pi}$	4			

Round



The luminaire shall be installed by a qualified electrician and wired in accordance with the latest IEE electrical regulations or the national requirements.



This marking indicates that this product should not be disposed with other household wastes throughout the EU. To prevent possible harm to the environment or human health from uncontrolled waste disposal, recycle it responsibly to promote the sustainable reuse of material resources. To return your used device, please use the return and collection systems or contact the retailer where the product was purchased. They can take this product for environmental safe recycling

Remarks

- 1. This luminaire uses permanent connection on power supply with flexible cable and wires (60245 IEC57). Sufficient length of cable is reserved for connection to AC power. Protection over the connection joint and elimination of tensile force there should be ensured.ufficient.
- 2. This luminaire uses type Y attachment: method of attachment of the cable or cord such that any replacement
- can only be made by the manufacturer, his service agent or similarly qualified person.
- 3. Wiring: the connection to AC power should be operated on terminal blocks in a wiring box with a degree of protection at least equivalent to the luminaire, and there should be devices to fixate wires.
- 4. The luminaire can be mounted onto ordinary combustible surfaces.